

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Pinedale Estates DWID Has Levels of Selenium Above Drinking Water Standards

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we did (are doing) to correct this situation.

We routinely monitor for the presence of drinking water contaminants. On 04/21/26, we received notice that the sample collected on 04/14/26 showed that our system exceeds the standard, or maximum contaminant level (MCL), for Selenium. The standard for Selenium is 0.05 Mg/L. This last sample showed the level of Selenium to be 0.38 Mg/L.

What should I do?

- There is nothing you need to do. **You do not need to** boil your **water** or take other corrective actions. However, if you have specific health concerns, consult your doctor.
- If you have a severely compromised immune system, have an infant, are pregnant, or are elderly, you may be at increased risk and should seek advice from your health care providers about drinking this water.

What does this mean?

This is not an emergency. If it had been, you would have been notified within 24 hours. However, If you have a severely compromised immune system, have an infant, are pregnant, or are elderly, you may be at increased risk and should seek advice from your health care providers about drinking this water.

What is being done?

PEDWID is providing alternate water at the new well at the North-East corner of 659 Petersen Lane. The well has been tested and is providing clean water below all of the maximum contaminant levels. Customers may use the well to meet their potable water needs. We have drilled a new well and the initial sample results show everything in compliance. A mainline extension, to tie this well into the existing system, has been finalized and the project is currently in its final stages.

For more information, please contact Mogollon Water Management at (928)251-0419 or admin@mogollonwater.com.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by PEDWID. State Water System ID#: AZ0409040.

Date distributed:04/27/2026